

**SHEET NOTES (X)** 

PROVIDE 4/0 AWG CU GROUNDING WIRE ROUTED ABOVE DUCTBANK. INTERCONNECT TO MANHOLE/HANDHOLE

LENGTH OF 4/0 AWG BARE CU STINGERS EXOTHERMICALLY WELDED TO DUCT BANK GROUND CONDUCTOR COILED AT END OF STUB OUTS. PROVIDE ABOVE GROUND MARKERS AT EACH STUB OUT FOR

SPACING BETWEEN DUCTS SHALL BE 10" ON CENTER, EXCEPT ON TEMPORARY SHIELDED DUCTS TO MCF,

- ENCASEMENT WHERE LOCATED UNDER AREAS OF HEAVY TRAFFIC LOAD. EXTEND ENCASEMENT 5 FEET BEYOND ROADWAYS. SEE E-100114A FOR EXTENT OF CONCRETE
- UON. SEE CIVIL FOR MV DUCT BANK BURIAL DEPTHS.
- PROVIDE PULL STRING ON SPARE DUCTS, AND PROVIDE WATER TIGHT CAP AT BOTH ENDS. APPLY LABEL TO EACH END OF THE PULL STRING NOTING LOCATION OF OTHER
- 5. SEE CP1-H, E-907107H, E-907741H, AND E-907742H FOR
- 6. FOR ELECTRICAL NOTES, LEGEND, AND ABBREVIATIONS,



Alaska District



Reference number: E-100301A

AM#9

/9\